

SOUTHWESTERN LABORATORIES

222 Cavalcade Street, 77009-3213
 P.O. Box 8768, Houston, Texas 77249-8768
 Tel (713) 692-9151 Fax (713) 696-6307

Attention: JG

VOBB - VEROT OAKS BUILDING BLOCKS, INC.
 P.O. BOX 62806
 Lafayette, LA 70596-2806
 P: 281-679-9357 / F: 248/282-5175

W/O. No.: VOB001-10-22-45499-1
 P.O. No.:
 Report Date: 10/23/2003
 Date of Service: 10/22/2003

Identification: Shaffer Block of Somerset, PA.
 Regular-Weight Aggregate for VOBBlock

PROJECT INFORMATION

Six Shaffer CMU blocks submitted for dimensional survey and weight determination.

SIZE: 6"

	LENGTH (in.)	WIDTH (in.)	HEIGHT (in.)	WEIGHT (lbs.)
	5.955	5.944	5.990	11.0
	5.971	5.956	6.017	11.0
Average	5.963	5.950	6.004	11.0


SIZE: 12"

	LENGTH (in.)	WIDTH (in.)	HEIGHT (in.)	WEIGHT (lbs.)
	11.947	5.955	6.052	21.0
	11.940	5.977	6.040	21.0
Average	11.944	5.966	6.046	21.0

SIZE: 18"

	LENGTH (in.)	WIDTH (in.)	HEIGHT (in.)	WEIGHT (lbs.)
	17.980	5.944	6.046	30.5
	17.971	5.957	6.082	31.0
Average	17.976	5.951	6.064	30.75

Respectfully Submitted


 Terry Wilt
 Manager, Product Evaluation

Our letters and reports are for the exclusive use of the client to whom they are addressed and shall not be reproduced except in full without the approval of the testing laboratory. The use of our name must receive our written approval. Our letters and reports apply only to the sample tested and/or inspected, and are not indicative of the quantities of apparently identical or similar products. Material submitted to our metals department will be discarded after a period of 30 days unless otherwise directed.
 Stork SWL is an operating unit of Stork Materials Technology B.V., Amsterdam, The Netherlands, which is a member of the Stork group