

05/29/2003 14:48

7136926205

STORK SWL

PAGE 01/01

STORK®**SWL****SOUTHWESTERN LABORATORIES**222 Cavalcade Street, 77009-3213
P.O. Box 8768, Houston, Texas 77249-8768
Tel (713) 692-9151 Fax (713) 696-9307*Attention: J.G.***VOBB - VEROT OAKS BUILDING BLOCKS, INC.**

P.O. BOX 62806

Lafayette, LA 70596-2806

P: 281-879-9357 / F: 248/282-5175

W/O. No.: VOB001-05-16-38093

P.O. No.: CK#3456

Report Date: 5/29/2003

Date of Service: 5/16/2003

Identification: VOBB PREMIER CONCRETE, CMU BLOCKS
Run: May 2003

PROJECT INFORMATION

Three VOBB Premier concrete masonry blocks submitted for dimensional survey.

DIMENSIONAL SPECIFICATIONS

Length (in.)	Width (in.)	Height (in.)	Face Shell (in.)	Web (in.)
17.948	5.946	6.046	1.605	1.271
17.934	5.952	6.056	1.521	1.058
17.942	5.944	6.050	1.517	1.045

Total Height 18.152
Average Height 6.051
Max variance 6/1000^{ths}

Our letters and reports are for the exclusive use of the client to whom they are addressed and shall not be reproduced except in full without the approval of the testing laboratory. The use of our name must receive our written approval. Our letters and reports apply only to the sample tested and/or inspected, and are not indicative of the quantities of apparently identical or similar products. Material submitted to our metals department will be discarded after a period of 30 days unless otherwise directed.

Respectfully Submitted



Stork SWL is an operating unit of Stork Materials Technology B.V., Amsterdam, The Netherlands, which is a member of the Stork group